



## Florida Building Code Informal Interpretation



**Date:** Tue Dec 21 2004

**Report #:** 3398

**Code:** Building

**Section:** 1917.4.1

**Question:**

If a 2004 state product approval for an insulating concrete includes G-60 galvanized coating as an approved steel deck, will this supercede the original 2000 FBC requirement for G-90 galvanized coating.

**Answer:**

If the Florida Building Commission approved the system for statewide use with G-60 galvanized deck it should be acceptable as an alternate method.

**Commentary:**

Careful attention to any limitations imposed by the Commission is absolutely necessary.

**Notice:**

*The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Community Affairs, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.*